Chapter 2 HVAC Fundamentals

TABLE 2.15A Solar Position and Intensity and Solar Heat Gain Factors for 40° North Latitude

| Date | Solar Time, · A.M. | Solar Position | | Direct Normal | Solar Heat Gain Factors, Btuh/ft ² | | | | | | | | | |
|--------|--------------------------|----------------|-----------|--|---|-----|------|------|-----|-----|-----|-----|------------|------------|
| | | Altitude | Azimuth | Irradiation, Btuh/ft² | N | NE | Е | SE | S | SW | w | NW | Horizontal | Tim P.N |
| Jan 21 | 8 | 8.1 | 55.3 | 141 | 5 | 17 | 111 | 133 | 75 | 5 | 5 | 5 | 13 | 4 |
| | 9 | 16.8 | 44.0 | 238 | 11 | 12 | 154 | 224 | 160 | 13 | 11 | 11 | 54 | 3 |
| | 10 | 23.8 | 30.9 | 274 | 16 | 16 | 123 | 241 | 213 | 51 | 16 | 16 | 96 | 2 |
| | 11 | 28.4 | 16.0 | 289 | 18 | 18 | 61 | 222 | 244 | 118 | 18 | 18 | 123 | 1 |
| | 12 | 30.0 | 0.0 | 293 | 19 | 19 | 20 | 179 | 254 | 179 | 20 | 19 | 133 | 12 |
| | | Half-Da | | 59 | 68 | 449 | 903 | 815 | 271 | 59 | 59 | 353 | | |
| Feb 21 | 7 | 4.3 | 72.1 | 55 | 1 | 22 | 50 | 47 | 13 | 1 | 1 | 1 | 3 | |
| | 8 | 14.8 | 61.6 | 219 | 10 | 50 | 183 | 199 | 94 | 10 | 10 | 10 | 43 | 4 |
| | 9 | 24.3 | 49.7 | 271 | 16 | 22 | 186 | 245 | 157 | 17 | 16 | 16 | 98 | 3 |
| | 10 | 32.1 | 35.4 | 293 | 20 | 21 | 142 | 247 | 203 | 38 | 20 | 20 | 143 | 1 |
| | 11 | 37.3 | 18.6 | 303 | 23 | 23 | 71 | 219 | 231 | 103 | 23 | 23 | 171 | 1 |
| | 12 | 39.2 | 0.0 | 306 | 24 | 24 | 25 | 170 | 241 | 170 | 25 | 24 | 180 | 12 |
| | | Half-Da | y Totals | | 81 | 144 | 634 | 1035 | 813 | 250 | 81 | 81 | 546 | |
| Mar 21 | 7 | 11.4 | 80.2 | 171 | 8 | 93 | 163 | 135 | 21 | 8 | 8 | 8 | 26 | |
| | 8 | 22.5 | 69.6 | 250 | 15 | 91 | 218 | 211 | 73 | 15 | 15 | 15 | 85 | 4 |
| | 9 | 32.8 | 57.3 | 281 | 21 | 46 | 203 | 236 | 128 | 21 | 21 | 21 | 143 | 1 |
| | 10 | 41.6 | 41.9 | 297 | 25 | 26 | 153 | 229 | 171 | 28 | 25 | 25 | 186 | |
| | 11 | 47.7 | 22.6 | 304 | 28 | 28 | 78 | 198 | 197 | 77 | 28 | 28 | 213 | |
| | 12 | 50.0 | 0.0 | 306 | 28 | 28 | 30 | 145 | 206 | 15 | 30 | 28 | 223 | 12 |
| | | Half-Da | y Totals | | 112 | 310 | 849 | 1100 | 692 | 218 | 112 | 112 | 764 | |
| Apr 21 | 6 | 7.4 | 98.9 | 89 | 11 | 72 | 88 | 52 | 5 | 4 | 4 | 4 | 11 | (|
| | 7 | 18.9 | 89.5 | 207 | 16 | 141 | 201 | 143 | 16 | 14 | 14 | 14 | 61 | |
| | 8 | 30.3 | 79.3 | 253 | 22 | 128 | 225 | 189 | 41 | 21 | 21 | 21 | 124 | 4 |
| | 9 | 41.3 | 67.2 | 275 | 26 | 80 | 203 | 204 | 83 | 26 | 26 | 26 | 177 | 3 |
| | 10 | 51.2 | 51.4 | 286 | 30 | 37 | 153 | 194 | 121 | 32 | 30 | 30 | 218 | 2 |
| | 11 | 58.7 | 29.2 | 292 | 33 | 34 | 81 | 161 | 146 | 52 | 33 | 33 | 244 | 1 |
| | 12 | 61.6 | 0.0 | 294 | 33 | 33 | 36 | 108 | 155 | 108 | 36 | 33 | 253 | 12 |
| | | Half-Da | iy Totals | | 153 | 509 | 969 | 1003 | 489 | 196 | 146 | 145 | 962 | |
| May 21 | 5 | 1.9 | 114.7 | 1 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 1 |
| | 6 | 12.7 | 105.6 | 143 | 35 | 128 | 141 | 71 | 10 | 10 | 10 | 10 | 30 | |
| | 7 | 24.0 | 96.6 | 216 | 28 | 165 | 209 | 131 | 20 | 18 | 18 | 18 | 87 | 1 |
| | 8 | 35.4 | 87.2 | 249 | 27 | 149 | 220 | 164 | 29 | 25 | 25 | 25 | 146 | 4 |
| | 9 | 46.8 | 76.0 | 267 | 31 | 105 | 197 | 175 | 53 | 30 | 30 | 30 | 196 | 1 |
| | 10 | 57.5 | 60.9 | 277 | 34 | 54 | 148 | 163 | 83 | 35 | 34 | 34 | 234 | 2 |
| | 11 | 66.2 | 37.1 | 282 | 36 | 38 | 81 | 130 | 105 | 42 | 36 | 36 | 258 | 1 |
| | 12 | 70.0 | 0.0 | 284 | 37 | 37 | 40 | 82 | 112 | 82 | 40 | 37 | 265 | 13 |
| | | Half-Da | y Totals | | 203 | 643 | 1002 | 874 | 356 | 194 | 171 | 170 | 1083 | |
| | | | | | | | | | | | | | | |

ALWAYS LEARNING Mechanical & Electrical Systems in Buildings, 5e Richard Janis, William Tao

© 2014 by Pearson Higher Education, Inc Upper Saddle River, New Jersey 07458 • All Rights Reserved

Chapter 2 HVAC Fundamentals

TABLE 2.15A (continued) Solar Position and Intensity and Solar Heat Gain Factors for 40° North Latitude TABLE 2.15A Continued

| | 2. | 15A Co | ontinued | | | | | | | | | | | |
|---------|-----------------|----------|----------|--------------------------------------|---|-----|------|------|-----|-----|-----|-----|------------|------------|
| | Solar | Solar F | osition | Direct Normal | Solar Heat Gain Factors, Btuh/ft ² | | | | | | | | | |
| Date | Time, ' A.M. | Altitude | Azimuth | Irradiation, Btuh/ft ² | N | NE | Е | SE | S | SW | w | NW | Horizontal | Tim P.N |
| June 21 | 5 | 4.2 | 117.3 | 21 | 10 | 21 | 20 | 6 | 1 | 1 | 1 | 1 | 2 | 7 |
| | 6 | 14.8 | 108.4 | 154 | 47 | 142 | 151 | 70 | 12 | 12 | 12 | 12 | 39 | 6 |
| | 7 | 26.0 | 99.7 | 215 | 37 | 172 | 206 | 122 | 21 | 20 | 20 | 20 | 97 | 5 |
| | 8 | 37.4 | 90.7 | 246 | 29 | 156 | 215 | 152 | 29 | 26 | 26 | 26 | 153 | 4 |
| | 9 | 48.8 | 80.2 | 262 | 33 | 113 | 192 | 161 | 45 | 31 | 31 | 31 | 201 | 3 |
| | 10 | 59.8 | 65.8 | 272 | 35 | 62 | 145 | 148 | 69 | 36 | 35 | 35 | 237 | - 2 |
| | 11 | 69.2 | 41.9 | 276 | 37 | 40 | 80 | 116 | 88 | 41 | 37 | 37 | 260 | |
| | 12 | 73.5 | 0.0 | 278 | 38 | 38 | 41 | 71 | 95 | 71 | 41 | 38 | 267 | 12 |
| | | Half-Da | y Totals | | 242 | 714 | 1019 | 810 | 311 | 197 | 181 | 180 | 1121 | |
| July 21 | 5 | 2.3 | 115.2 | 2 | 0 | 2 | 1 | 0 | 0 | 0 | 0 | 0 | 0 | 1 |
| | 6 | 13.1 | 106.1 | 137 | 37 | 125 | 137 | 68 | 10 | 10 | 10 | 10 | 31 | (|
| | 7 | 24.3 | 97.2 | 208 | 30 | 163 | 204 | 127 | 20 | 19 | 19 | 19 | 88 | |
| | 8 | 35.8 | 87.8 | 241 | 28 | 148 | 216 | 160 | 29 | 26 | 26 | 26 | 145 | 4 |
| | 9 | 47.2 | 76.7 | 259 | 32 | 106 | 194 | 170 | 52 | 31 | 31 | 31 | 194 | 3 |
| | 10 | 57.9 | 61.7 | 269 | 35 | 56 | 146 | 159 | 80 | 36 | 35 | 35 | 231 | 1 |
| | 11 | 66.7 | 37.9 | 274 | 37 | 39 | 81 | 127 | 102 | 42 | 37 | 37 | 255 | 1 |
| | 12 | 70.6 | 0.0 | 276 | 38 | 38 | 41 | 80 | 109 | 80 | 41 | 38 | 282 | 12 |
| | | Half-Da | y Totals | | 211 | 645 | 986 | 850 | 347 | 197 | 177 | 176 | 1074 | |
| Aug 21 | 6 | 7.9 | 99.5 | 80 | 12 | 67 | 82 | 48 | 5 | 5 | 5 | 5 | 11 | (|
| | 7 | 19.3 | 90.0 | 191 | 17 | 135 | 191 | 135 | 17 | 15 | 15 | 15 | 62 | |
| | 8 | 30.7 | 79.9 | 236 | 23 | 126 | 216 | 180 | 40 | 22 | 22 | 22 | 122 | 4 |
| | 9 | 41.8 | 67.9 | 259 | 28 | 82 | 197 | 196 | 79 | 28 | 28 | 28 | 174 | 1 |
| | 10 | 51.7 | 52.1 | 271 | 32 | 40 | 149 | 187 | 116 | 34 | 32 | 32 | 213 | |
| | 11 | 50.3 | 29.7 | 277 | 34 | 35 | 81 | 156 | 140 | 52 | 34 | 34 | 238 | 1 |
| | 12 | 62.3 | 0.0 | 279 | 35 | 35 | 38 | 105 | 149 | 105 | 38 | 35 | 247 | 1: |
| | | Half-Da | y Totals | | 161 | 503 | 936 | 961 | 471 | 202 | 154 | 153 | 945 | |
| Sep 21 | 7 | 11.4 | 80.2 | 149 | 8 | 84 | 146 | 121 | 21 | 8 | 8 | 8 | 25 | |
| | 8 | 22.5 | 69.6 | 230 | 16 | 86 | 205 | 199 | 71 | 16 | 16 | 16 | 82 | 4 |
| | 9 | 32.8 | 57.3 | 263 | 22 | 47 | 195 | 226 | 124 | 23 | 22 | 22 | 138 | 1 |
| | 10 | 41.6 | 41.9 | 279 | 26 | 28 | 148 | 221 | 165 | 30 | 26 | 26 | 180 | 1 |
| | | 47.7 | 22.6 | 287 | 29 | 29 | 77 | 192 | 191 | 77 | 29 | 29 | 206 | 1 |
| | 12 | 50.0 | 0.0 | 290 | 30 | 30 | 32 | 141 | 200 | 141 | 32 | 30 | 215 | 12 |
| | | Half-Da | y Totals | | 116 | 300 | 803 | 1045 | 672 | 221 | 117 | 116 | 738 | |
| Oct 21 | 7 | 4.5 | 72.3 | 48 | 1 | 20 | 45 | 41 | 12 | 1 | 1 | 1 | 3 | |
| | 8 | 15.0 | 61.9 | 203 | 10 | 49 | 173 | 187 | 88 | 10 | 10 | 10 | 43 | 4 |
| | 9 | 24.5 | 49.8 | 257 | 17 | 23 | 180 | 235 | 151 | 18 | 17 | 17 | 96 | 3 |
| | 10 | 32.4 | 35.6 | 280 | 21 | 22 | 139 | 238 | 196 | 38 | 21 | 21 | 140 | 2 |
| | 11 | 37.6 | 18.7 | 290 | 23 | 23 | 70 | 212 | 224 | 100 | 23 | 23 | 167 | 1 |
| | 12 | 39.5 | 0.0 | 293 | 24 | 24 | 26 | 165 | 234 | 165 | 26 | 24 | 177 | 12 |
| | | Half-Da | y Totals | | 83 | 143 | 610 | 989 | 783 | 245 | 84 | 83 | 535 | |
| | | | | | N | NW | w | SW | s | SE | E | NE | Horizontal | |

ALWAYS LEARNING Mechanical & Electrical Systems in Buildings, 5e Richard Janis, William Tao

© 2014 by Pearson Higher Education, Inc Upper Saddle River, New Jersey 07458 • All Rights Reserved



Chapter 2 HVAC Fundamentals

PEARSON

TABLE 2.15A (*continued***)** Solar Position and Intensity and Solar Heat Gain Factors for 40° North Latitude

| Date | Solar Time, ⁻ A.M. | Solar Position | | Direct Normal | Solar Heat Gain Factors, Btuh/ft ² | | | | | | | | | |
|--------|-------------------------------------|----------------|----------|---|---|----|-----|-----|-----|-----|----|----|------------|---------------|
| | | Altitude | Azimuth | Irradiation, - Btuh/ft² | N | NE | Е | SE | S | SW | w | NW | Horizontal | Time, P.M. |
| Nov 21 | 8 | 0.2 | 55.4 | 136 | 5 | 17 | 107 | 128 | 72 | 5 | 5 | 5 | 14 | 4 |
| | 9 | 17.0 | 44.1 | 232 | 12 | 13 | 151 | 219 | 156 | 13 | 12 | 12 | 54 | 3 |
| | 10 | 24.0 | 31.0 | 267 | 16 | 16 | 122 | 237 | 209 | 50 | 16 | 16 | 96 | 2 |
| | 11 | 28.6 | 16.1 | 283 | 19 | 19 | 61 | 218 | 240 | 116 | 19 | 19 | 123 | 1 |
| | 12 | 30.2 | 0.0 | 287 | 19 | 19 | 21 | 176 | 250 | 176 | 21 | 19 | 132 | 12 |
| | Half-Day Totals | | | | | 71 | 442 | 884 | 798 | 267 | 62 | 61 | 353 | |
| Dec 21 | 8 | 5.5 | 53.0 | 88 | 2 | 7 | 67 | 83 | 49 | 3 | 2 | 2 | 6 | 4 |
| | 9 | 14.0 | 41.9 | 217 | 9 | 10 | 135 | 205 | 151 | 12 | 9 | 9 | 39 | 3 |
| | 10 | 20.7 | 29.4 | 261 | 14 | 14 | 113 | 232 | 210 | 55 | 14 | 14 | 77 | 2 |
| | 11 | 25.0 | 15.2 | 279 | 16 | 16 | 56 | 217 | 242 | 120 | 16 | 16 | 103 | 1 |
| | 12 | 26.6 | 0.0 | 284 | 17 | 17 | 18 | 177 | 253 | 177 | 18 | 17 | 113 | 12 |
| | | Half-Da | y Totals | | 49 | 54 | 380 | 831 | 781 | 273 | 50 | 49 | 282 | |
| | | | | | N | NW | w | SW | s | SE | E | NE | Horizontal | , ∠P.M |

Data shown in table is for 40° north latitude. Solar intensity is given in the Direct Normal column. Solar heat gain factor is the peak heat gain of the hour calculated with clearness factor = 1.0 and ground reflectance = 0.20. Half-day total is the average heat gain based on Simpson's rule on 10-minute interval. See ASHRAE Handbook of Fundamentals for data of other latitudes (16, 24, 32, 48, 56, and 64).

Source: Reprinted by permission from ASHRAE (www.ashrae.org).

ALWAYS LEARNING Mechanical & Electrical Systems in Buildings, 5e Richard Janis, William Tao

© 2014 by Pearson Higher Education, Inc Upper Saddle River, New Jersey 07458 • All Rights Reserved